

Certificate of Compliance

Certificate Number 071004 - E198546
Report Reference E198546, September 3rd, 2004
Issue Date 2004 October 7

Page 1 of 2



**Underwriters
Laboratories Inc.®**

Issued to:

GEFRAN SPA

VIA SEBINA 74
I-25050 PROVAGLIO D'ISEO BRESCIA ITALIA

*This is to certify that
representative samples of*

Programmable Controllers

Cat. No. 1200, 1300, 4T96, 40T96,
4B96, 40B96 (see nomenclature breakdown for details)

*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate.*


Standard(s) for Safety:

**UL 508 - Industrial Control Equipment
CSA C22.2 No. 14-M95 - Industrial Control Equipment**

Additional Information:

See Addendum for Electrical Rating

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by:

Matteo Redaelli /BC

Matteo Redaelli - Engineering Team Leader

Reviewed by:

Giuseppe Redaelli /BC

Giuseppe Redaelli - Senior Project Engineer

UL International Italia Srl

UL International Italia Srl

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc.
For questions in Italy, you may call +39 079 2636600.

Certificate of Compliance

Certificate Number 071004 - E198546
Report Reference E198546, September 3rd, 2004
Issue Date 2004 October 7

Page 2 of 2



**Underwriters
Laboratories Inc.**

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL and cUL requirements.

Electrical Ratings:

Power Supply Input: 11 - 27 Vac/dc $\pm 10\%$, 11 VA max, frequency 50-60 Hz.
100 - 240 Vac/dc $\pm 10\%$, 18 VA max, frequency 50-60 Hz.

Output Ratings:

Relay: 250 Vac, 5 A Resistive

Logic: 11 Vdc $\pm 10\%$

Analogue: 0 - 10 V or 0 - 50 mA

Issued by

Matteo Redaelli / B.C.

Matteo Redaelli - Engineering Team Leader

UL International Italia Srl

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc./UL International Italia Srl.

Reviewed by

Giuseppe Redaelli / B.C.

Giuseppe Redaelli - Senior Project Engineer

UL International Italia Srl